

Issued 30-07-2010 Scope KIWA KQ  
Report number KQI-100500138

## KIWA KQ Batch Inspection Approval

Herewith KIWA Italia Spa, according to KIWA KQ Batch Inspection, declares the products :

Type:	Safe Water Legionella Filters
Serial number:	HELI-JPN from 10-01-00000 to 10-01-07999 (total 8.000 pieces)
User:	AquaServa Hendrik Walaardt Sacrestraat 435 1117 BM Schipol, - The Netherlands
Inspection site address:	Jan Valsterweg 65 Dordrecht The Netherlands

Comply with the KIWA KQ Batch Inspection requirements, based upon the following aspects:

Site inspection, according to the document Q10025AS-05-rev2, which includes:


- inspection of the Safe Water Legionella Filters batch, in order to check the unique production identification numbers;
- inspection of the packaging, manual/instruction and labelling products ;
- Select sampling randomly, needs to be analyzed according to ISO 2859-1:1999 (level II AQL 0,65) "Sampling procedures for inspection by attribute - sampling scheme indexed by acceptances quality limit for lot-by-lot inspection".

Laboratory Testing of the Safe Water Legionella Filter, which are performed by an accredited laboratory in accordance to EN ISO/IEC 17025:2005, using the following standards:

- NEN 6265:2007 "water - detection and enumeration of Legionella";

This declaration is issued in accordance with the Kiwa- regulations for Product Certification. Publication of the declaration is allowed.

Kiwa Italia Spa,

  
Ing. R. Karel,  
Director Product Certification

**kQ**  
kiwaQuality